




CHIEF ENGINEER

Official Publication of The Chief Engineers Association of Chicagoland
SINCE 1934

October 2018

TEMPORARY STRUCTURE SHOOTOUT: VRF VS. ELECTRIC RESISTANCE



Advanced Anti-Corrosion Coating Utilized on Two North Sea Offshore Platforms

Portable Friction Testing Can Prevent Slip-and-Fall Accidents and Deter Costly Liability

NEWS

Designing Dust Collectors With Expert Guidance

Dust collectors are used to capture, convey, and collect dust for a wide variety of manufacturing and industrial processes. Whether involving wood, plastic, metal or chemical dust particles, this is done to improve safety by reducing fire, explosion and dust inhalation hazards.

When it comes to dust collection, however, the challenge for mechanical engineers (MEs) is that, by definition, mechanical engineering is one of the broadest engineering disciplines. As such, they are often tasked with designing machinery or systems that provide a variety of functions, including generating power/electricity; conveying people/materials; and furnishing HVAC/refrigeration.

With such a broad focus, MEs are often unfamiliar with some of the technicalities of dust collection safety code compliance, since dust collection systems account for just a tiny fraction of their work.

When MEs have questions regarding dust collection on topics ranging from airflow to meeting NFPA and IMC codes, seek-



ing guidance from an industry expert can help to achieve compliance, safe performance, and better indoor air quality.

Design Challenges

Since dust collection is so important for safety — and



NIULPE, INC.

National Institute for the Uniform Licensing of Power Engineers, Inc.

**Already have a City of Chicago license?
Then you can get your NIULPE license as well. Call today for information.**

Levels of Certification

Fifth Class Engineer
Fourth Class Engineer
Third Class Engineer
Second Class Engineer
First Class Engineer
Chief Engineer

Legislation is changing QUICKLY!

Call the office today and find out how these changes may affect you!

**910 W. VanBuren #220 • Chicago, IL 60607
Ph: 888.648.5566 • Fax: 888.648.5577**

12845 S. CICERO ALSIP, IL 60803



Reliable



Fire & Security

www.reliablefire.com

Since 1955 - One Call Gives You Complete Fire, Security and Life Safety Solutions



The Complete Fire Protection Company

FIRE ALARM DIVISION

- Fire Alarm Systems
 - High Rise Systems
 - Voice Evacuation
 - 1 way – 2 way communication
 - Elevator Recall
 - Door Unlocking
 - Annunciators
- Pre-action Sprinkler Systems
- Air Sampling Systems
- System Integration
- U.L. Certified

FIRE SUPPRESSION DIVISION

- Restaurant Hood & Duct Systems
- Halon 1301 Systems
- FM200 Systems
- Inergen and ProInert Systems
- Ecaro-25 Systems
- Novec 1230 Systems
- CO2 Systems
- Foam Systems
- Explosion Suppression Systems

SECURITY DIVISION

- Card Access Readers
- Biometric Readers
- Proximity Readers
- Closed Circuit TV
- Mega Pixel Cameras
- High Resolution Monitors
- DVR/NVR

PORTABLES DIVISION

- Fire Extinguishers
- Fire Hose
- Safety Equipment
- Fire Training Program

UL CENTRAL STATION/MONITORING

- Sprinkler Alarm/Service
- Security Systems
- Fire Alarm Systems

EMERGENCY LIGHTS DIVISION

- Emergency Lights
- Exit Signs

FIRST AID EQUIPMENT

- First Aid/CPRI/AED Training

ILLINOIS FIRE EQUIPMENT DISTRIBUTOR LICENSE #0037 ABC
ILLINOIS FIRE SPRINKLER CONTRACTOR LICENSE #FSC-0264
ILLINOIS FIRE ALARM CONTRACTOR LICENSE #127-000380
UL AUTHORIZED TO ISSUE UL CERTIFICATE FOR ALARM SYSTEMS (#S4055)
NICET CERTIFIED TECHNICIANS

ONE CALL DOES IT ALL!™

24 Hour Service – Over 50 Service Trucks • Chicago • Suburbs • Indiana
email: fire@reliablefire.com Ph: 708-597-4600 fax: 708-389-1150



depends on factors such as the dust sources, air filtration, facility usage, and HVAC — it often has to be customized and not based on previous design plans.

Peter Levitt, a NFPA member, who for over two decades has been a committee member of NFPA 664, which oversees revisions of the woodworking code, outlines the five main components of a dust collection system.

These components include a hood to confine the dust at its source; a duct system to convey the dust; a fan to provide hood suction and maintain transport velocity in the ducts; a collector to separate the dust from the air stream and a device to store the collected dust.

“When dealing with dust collection, MEs often have questions about duct sizing, and how much air to allocate for suction at the hood and at each woodworking machine,” says Levitt. “They may not know what the velocity should be in the ducts, and often do not know what the code specifies for the dust collection system.”

Levitt notes that a properly designed and maintained dust collection system will dramatically enhance shop safety. This can not only reduce the risk of dust explosion and fire, but also help to minimize any dust inhalation while improving indoor air quality.

“MEs are often not aware of the incompatibility of some machines, materials and processes for a dust collection system,” says Levitt.

As an example, he cites a relatively common mistake. “In a wood shop you might have a grinding wheel to sharpen tools,” he says. “However, you cannot have common suction at the grinder because any sparks produced could ignite the wood dust and trigger a fire or explosion. So the grinder cannot be part of the dust collection system.”

He adds that for a similar reason, PVC ducts should not be used with a dust collection system. The problem is that if static electricity is generated by the dust being conveyed in the duct, it can also cause a dust explosion.

Best Practice Dust Control

To help MEs learn best practice options for dust control, Levitt, who is also a product manager at Sternvent, Inc., conducts lunch and learn presentations at engineering firms.

Union, N.J.-based Sternvent has more than 50 years of experience in the design, manufacture and application of dust collection systems. The company, which specializes in systems for the wood, metal finishing and chemical industries, provides up-to-date guidance for compliance with NFPA, OSHA and IMC.

In the presentations, Levitt covers topics such as determining the location of the dust collector, explosion venting, spark detection/suppression, and NFPA 664 recommended exhaust requirements. He also surveys the range of dust collection system equipment choices from indoor enclosureless positive pressure to outdoor shaker and pulse jet types.

While Levitt provides guidance, he defers sales to the Sternvent network of professional sales representatives, who have developed ongoing, trusted relationships with MEs.

One aspect of dust collection that needs more attention is the design of the ductwork, according to Levitt. “For good airflow, good ductwork is essential. Even with a powerful dust collector, if the ductwork is not designed properly, you will have so much airflow resistance you won’t have enough airflow or suction.”

Another aspect that he says often needs consideration is whether the dust collector is located indoors or outdoors and how that affects filtered air.

“Typically, the dust collector is located outdoors for fire safety,” says Levitt. “However, in regards to filtered air, if you don’t return it properly, then in winter you will have a hard time heating the building. The result is like having a fan exhausting the warm indoor air outside.”

While many factors should be examined in designing a safe and effective dust collection system, it is also important to not over-specify it.

“If a dust collector is oversized, it will not only cost more than required, but also create excessive noise due to high velocity airflow in the ducts,” concludes Levitt. “Knowing your options up front by collaborating with an expert can help MEs deliver the best equipment for the situation at the best price.”

For more info, call 908-688-0807; Fax: 908-688-0718; email Peter Levitt: plevitt@sternvent.com; visit www.sternvent.com; or write to Sternvent, Inc. at 5 Stahuber Ave, Union, NJ 07083. 